

DOCUMENT CODE
CP142-CAS-9211.3

Master S.r.l., declares that:

FAST MOUNTING HINGE TOP RAPID ART. 9211.3

Passed the test according to:
DURABILITY FOR HINGES TO USE
ON DOORS AND WINDOWS
200.000 CYCLE – (60 kg)

On a test rig:

PNEUMATIC ACTUATOR

With this test parameters:

MASS: 60Kg

frequency: 600 cycle/h

Classification for the hinge:

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion resistance	Security	Grade
1	2	3	4	5	6	7	8
2	7	3	0	1	4	0	10

According to:

UNI EN 13126-1:2006

UNI EN 1935 :2004

UNI EN 1670:2007

Date of issue: 04/01/2012

Maria Luigia Lacatena
Amministratore Unico MASTER srl

La presente dichiarazione è basata su specifiche di prova stabilite internamente da MASTER srl
MASTER srl si riserva il diritto di variare le caratteristiche tecniche dei suoi prodotti, senza preavviso ed in ogni momento.
Tutti i diritti sono riservati. E' fatto divieto di qualunque riproduzione parziale o totale dei presenti documenti.